

Building Name: Small Residence Unit
Street Address: 203 N. Union St
Year Built: 1890
Occupancy: Residence Hall
Capacity: 16 Beds
Type of Construction: Frame

Fire Alarm System Description

Fire Alarm Panel: Honeywell Fire Lite MS 9050

General Description: Fire alarm system consists of manual pull stations, visual/audible alarm devices and integrated automatic detection devices; addressable smoke detector/sounder bases and heat detectors located in individual sleeping rooms, corridors, common areas and mechanical spaces.

Fire Alarm Testing and Inspection

Individual components of the fire alarm systems are tested annually by a certified fire alarm company in accordance with NFPA 72, National Fire Alarm Code.

Portable Fire Extinguishers

Fire extinguishers are located in accordance with NFPA 10, Stan